

Compact Switch Module CSM 1277 for connecting SIMATIC S7-1200 and up to 3 further nodes to Industrial Ethernet with 10/100 Mbit/s; unmanaged switch, 4 RJ45 ports, ext. 24 V DC power supply LED diagnostics, S7-1200 module incl. electronic Equipment Manual on CD-ROM



<b>Product type designation</b>	<b>SCALANCE CSM 1277</b>
<b>Transmission rate</b>	
Transfer rate	10 Mbit/s, 100 Mbit/s
<b>Interfaces / for communication / integrated</b>	
Number of electrical connections	
• for network components or terminal equipment	4
Number of 100 Mbit/s SC ports	
• for multimode	0
Number of 1000 Mbit/s LC ports	
• for multimode	0
• for single mode (LD)	0
<b>Interfaces / others</b>	
Number of electrical connections	
• for power supply	1
Type of electrical connection	
• for power supply	3-pole terminal block
<b>Supply voltage, current consumption, power loss</b>	

Type of voltage / of the supply voltage	DC
Supply voltage	
• external	24 V
• external / minimum	19.2 V
• external / maximum	28.8 V
Product component / fusing at power supply input	Yes
Fuse protection type / at input for supply voltage	0.5 A / 60 V
Consumed current / maximum	0.07 A
Power loss [W]	
• at DC / at 24 V	1.6 W

### Permitted ambient conditions

Ambient temperature	
• during operation	0 ... 60 °C
• during storage	-40 ... +70 °C
• during transport	-40 ... +70 °C
Relative humidity	
• at 25 °C / without condensation / during operation / maximum	95 %
Protection class IP	IP20

### Design, dimensions and weight

Design	SIMATIC S7-1200 device design
Width	45 mm
Height	100 mm
Depth	75 mm
Net weight	0.15 kg
Mounting type	
• 35 mm DIN rail mounting	Yes
• wall mounting	Yes
• S7-300 rail mounting	No
• S7-1500 rail mounting	No

### Product functions / management, configuration

Product function	
• multiport mirroring	No
Product function / switch-managed	No

### Product functions / Redundancy

Product function	
• Parallel Redundancy Protocol (PRP)/operation in the PRP-network	Yes
• Parallel Redundancy Protocol (PRP)/Redundant Network Access (RNA)	No

### Standards, specifications, approvals

Standard	
<ul style="list-style-type: none"> <li>• for FM</li> </ul>	FM3611: Class 1, Divison 2, Group A, B, C, D / T.., CL.1, Zone 2, GP. IIC, T.. Ta
<ul style="list-style-type: none"> <li>• for hazardous zone</li> </ul>	EN 600079-15:2005, EN 600079-0:2006, II 3 G Ex nA II T4, KEMA 08 ATEX 0003 X
<ul style="list-style-type: none"> <li>• for safety / from CSA and UL</li> </ul>	UL 508, CSA C22.2 No. 142
<ul style="list-style-type: none"> <li>• for emitted interference</li> </ul>	EN 61000-6-4 (Class A)
<ul style="list-style-type: none"> <li>• for interference immunity</li> </ul>	EN 61000-6-2

Standards, specifications, approvals / CE	
Certificate of suitability / CE marking	Yes

Standards, specifications, approvals / miscellaneous	
Certificate of suitability	EN 61000-6-2, EN 61000-6-4
<ul style="list-style-type: none"> <li>• C-Tick</li> </ul>	Yes
<ul style="list-style-type: none"> <li>• KC approval</li> </ul>	No

Standards, specifications, approvals / ship classification	
Marine classification association	
<ul style="list-style-type: none"> <li>• American Bureau of Shipping Europe Ltd. (ABS)</li> </ul>	Yes
<ul style="list-style-type: none"> <li>• Bureau Veritas (BV)</li> </ul>	Yes
<ul style="list-style-type: none"> <li>• Det Norske Veritas (DNV)</li> </ul>	Yes
<ul style="list-style-type: none"> <li>• Germanische Lloyd (GL)</li> </ul>	No
<ul style="list-style-type: none"> <li>• Lloyds Register of Shipping (LRS)</li> </ul>	Yes
<ul style="list-style-type: none"> <li>• Nippon Kaiji Kyokai (NK)</li> </ul>	Yes
<ul style="list-style-type: none"> <li>• Polski Rejestr Statkow (PRS)</li> </ul>	No
<ul style="list-style-type: none"> <li>• Royal Institution of Naval Architects (RINA)</li> </ul>	No

Standards, specifications, approvals / product conformity	
MTBF	273 y

Further Information / Internet Links	
Internet-Link	
<ul style="list-style-type: none"> <li>• to website: Selector SIMATIC NET SELECTION TOOL</li> </ul>	<a href="http://www.siemens.com/snst">http://www.siemens.com/snst</a>
<ul style="list-style-type: none"> <li>• to website: Industrial communication</li> </ul>	<a href="http://www.siemens.com/simatic-net">http://www.siemens.com/simatic-net</a>
<ul style="list-style-type: none"> <li>• to website: Industry Mall</li> </ul>	<a href="https://mall.industry.siemens.com">https://mall.industry.siemens.com</a>
<ul style="list-style-type: none"> <li>• to website: Information and Download Center</li> </ul>	<a href="http://www.siemens.com/industry/infocenter">http://www.siemens.com/industry/infocenter</a>
<ul style="list-style-type: none"> <li>• to website: Image database</li> </ul>	<a href="http://automation.siemens.com/bilddb">http://automation.siemens.com/bilddb</a>
<ul style="list-style-type: none"> <li>• to website: CAx Download Manager</li> </ul>	<a href="http://www.siemens.com/cax">http://www.siemens.com/cax</a>
<ul style="list-style-type: none"> <li>• to website: Industry Online Support</li> </ul>	<a href="https://support.industry.siemens.com">https://support.industry.siemens.com</a>

## Security information

---

Security information

Siemens provides products and solutions with industrial security functions that support the secure operation of plants, solutions, machines, equipment and/or networks. They are important components in a holistic industrial security concept. With this in mind, Siemens' products and solutions undergo continuous development. Siemens recommends strongly that you regularly check for product updates. For the secure operation of Siemens products and solutions, it is necessary to take suitable preventive action (e.g. cell protection concept) and integrate each component into a holistic, state-of-the-art industrial security concept. Third-party products that may be in use should also be considered. For more information about industrial security, visit <http://www.siemens.com/industrialsecurity>. To stay informed about product updates as they occur, sign up for a product-specific newsletter. For more information, visit <http://support.automation.siemens.com>. (V3.4)

**last modified:**

08/27/2019