SIEMENS

Data sheet

6AG1511-1AK01-2AB0



SPARE PART SIPLUS S7-1500 CPU 1511-1 PN -40... +60°C start up -20°C with conformal coating based on 6ES7511-1AK01-0AB0. CENTRAL PROCESSING UNIT WITH WORKING MEMORY 150 KB FOR PROGRAM AND 1 MB FOR DATA, 1. INTERFACE: PROFINET IRT WITH 2 PORT SWITCH, 60 NS BIT-PERFORMANCE, SIMATIC MEMORY CARD NECESSARY

Figure similar

General information	
Product type designation	CPU 1511-1 PN
Display	
Screen diagonal [cm]	3.45 cm
	5.45 GH
Control elements	
Number of keys	6
Mode selector switch	1
Supply voltage	
Type of supply voltage	24 V DC
permissible range, lower limit (DC)	19.2 V
permissible range, upper limit (DC)	28.8 V
Input current	
Current consumption (rated value)	0.7 A
Inrush current, max.	1.9 A; Rated value
l²t	0.34 A ² ·s

Power	
Infeed power to the backplane bus	10 W
Power consumption from the backplane bus (balanced)	5.5 W
Power loss	
Power loss, typ.	5.7 W
Memory	
SIMATIC memory card required	Yes
Work memory	
 integrated (for program) 	150 kbyte
 integrated (for data) 	1 Mbyte
Load memory	
 Plug-in (SIMATIC Memory Card), max. 	2 Gbyte
Backup	
maintenance-free	Yes
CPU processing times	
for bit operations, typ.	60 ns
for word operations, typ.	72 ns
for fixed point arithmetic, typ.	96 ns
for floating point arithmetic, typ.	384 ns
CPU-blocks Number of blocks (total)	2 000
DB	2 000
Number, max.	2 000; Number range: 1 to 65535
• Size, max.	1 Mbyte
FB	
Number, max.	1 998; Number range: 1 to 65535
• Size, max.	150 kbyte
FC	
Number, max.	1 999; Number range: 1 to 65535
• Size, max.	150 kbyte
OB	
• Size, max.	150 kbyte
Number of free cycle OBs	100
Number of time alarm OBs	20
Number of delay alarm OBs	20
-	20
Number of cyclic interrupt OBs	20 50
Number of cyclic interrupt OBsNumber of process alarm OBs	50
 Number of cyclic interrupt OBs Number of process alarm OBs Number of DPV1 alarm OBs 	50 3
Number of cyclic interrupt OBsNumber of process alarm OBs	50

 Number of startup OBs 	100
 Number of asynchronous error OBs 	4
 Number of synchronous error OBs 	2
 Number of diagnostic alarm OBs 	1
Nesting depth	
● per priority class	24
Counters, timers and their retentivity	
S7 counter	
Number	2 048
Retentivity	
— adjustable	Yes
IEC counter	
Number	Any (only limited by the main memory)
Retentivity	
— adjustable	Yes
S7 times	
Number	2 048
Retentivity	
— adjustable	Yes
IEC timer	
Number	Any (only limited by the main memory)
Retentivity	
— adjustable	Yes
Data areas and their retentivity Retentive data area (incl. timers, counters, flags),	128 kbyte; Available retentive memory for bit memories, timers,
max.	counters, DBs, and technology data (axes): 88 KB
Flag	
• Number, max.	16 kbyte
 Number of clock memories 	8; 8 clock memory bit, grouped into one clock memory byte
Data blocks	
 Retentivity adjustable 	Yes
Retentivity preset	No
Local data	
• per priority class, max.	64 kbyte; max. 16 KB per block
Address area	
Number of IO modules	1 024
I/O address area	
Inputs	32 kbyte; All inputs are in the process image
Outputs	32 kbyte; All outputs are in the process image
per integrated IO subsystem	
— Inputs (volume)	8 kbyte
/	

— Outputs (volume)	8 kbyte
per CM/CP	
— Inputs (volume)	8 kbyte
— Outputs (volume)	8 kbyte
Subprocess images	
Number of subprocess images, max.	32
Hardware configuration	
Number of distributed IO systems	20
Number of DP masters	
• Via CM	4; A maximum of 4 CMs/CPs (PROFIBUS, PROFINET, Ethernet) can be inserted in total
Number of IO Controllers	
• integrated	1
Rack	
 Modules per rack, max. 	32; CPU + 31 modules
 Number of lines, max. 	1
PtP CM	
Number of PtP CMs	the number of connectable PtP CMs is only limited by the number of available slots
Time of day	
Clock	
• Туре	Hardware clock
Backup time	6 wk; At 40 °C ambient temperature, typically
 Deviation per day, max. 	10 s; Typ.: 2 s
Clock synchronization	
• supported	Yes
• in AS, master	Yes
• in AS, slave	Yes
• on Ethernet via NTP	Yes
Interfaces Number of PROFINET interfaces	1
1. Interface	
Interface types	
Number of ports	2
 integrated switch 	Yes
• RJ 45 (Ethernet)	Yes
Protocols	
PROFINET IO Controller	Yes
PROFINET IO Device	Yes
 SIMATIC communication 	Yes
Open IE communication	Yes

• Media redundancy Yes Interface types R145 (Ethernet) F100 Mbps Yes • Autorospoliation Yes • Number of connections, max. 96 • Number of connections reserved for 10 • Strikter 64 • Number of connections via integrated 64 • Number of connections via integrated 64 • Number of connections via integrated 64 • Number of connections made Yes - PG/OP communication Yes - S7 routing Yes - Open IE communication Yes - S7 routing Yes Max 32 PROFINET devices - IRT Yes Max 32 PROFINET devices - PROFIenergy Yes - Of which IO devices with IRT, max. 64 - Number of OD nevices for RT, max. 64 - Number of IO Devices per tool, max. 8 - Mumber of IO Devices per tool, max.<	Web server	Yes
RJ 45 (Ethernet) Yes • 100 Mbps Yes • Autonegotiation Yes • Autonegotiation Yes • Autorecossing Yes • Industrial Ethernet status LED Yes Protocols 96 • Number of connections, max. 96 • Number of connections reserved for 10 ES/HMI/web 64 • Number of connections via integrated interfaces 64 PROFINET IO Controller Services - PC/OP communication Yes - IRT Yes - loopen IE communication Yes - Open IE communication Yes - Number of connectable IO Devices, max. 128, In total, up to 256 distributed I/O devices can be connected via CPs/CMs via PROFIBUS or PROFINET. - Number of connectable IO Devices, max. 128, In total, up to 256 distributed I/O devices can be connected via CPs/CMs via PROFIBUS or PROFINET. - Of which I/O devices with IRT, max. 64 - Number of IO Devices for RT, 128 128 max. 128 - of which II ine, max. 128 - Wumber of IO Devices that can be simultaneously activated/deductideductant, max. 6	Media redundancy	Yes
RJ 45 (Ethernet) Yes • 100 Mbps Yes • Autonegotiation Yes • Autonegotiation Yes • Autorecossing Yes • Industrial Ethernet status LED Yes Protocols 96 • Number of connections, max. 96 • Number of connections reserved for 10 ES/HMI/web 64 • Number of connections via integrated interfaces 64 PROFINET IO Controller Services - PC/OP communication Yes - IRT Yes - loopen IE communication Yes - Open IE communication Yes - Number of connectable IO Devices, max. 128, In total, up to 256 distributed I/O devices can be connected via CPs/CMs via PROFIBUS or PROFINET. - Number of connectable IO Devices, max. 128, In total, up to 256 distributed I/O devices can be connected via CPs/CMs via PROFIBUS or PROFINET. - Of which I/O devices with IRT, max. 64 - Number of IO Devices for RT, 128 128 max. 128 - of which II ine, max. 128 - Wumber of IO Devices that can be simultaneously activated/deductideductant, max. 6	Interface turner	
• 100 Mbps Yes • Autorospotiation Yes • Autocrossing Yes • Industrial Ethernet status LED Yes Protocols ************************************		
AutoergotiationYesAutoergosingYesIndustrial Ethernet status LEDYesProteoolsNumber of connections, max.96Number of connections reserved for10ES/HMI/web64Number of connections via integrated interfaces64PROFINET IO Controller7ServicesYes- PG/GOP communicationYes- S7 routingYes- S7 routingYes- Sochronous modeYes- S7 routingYes- Number of connectable IO Devices, max.128. In total, up to 256 distributed I/O devices can be connected via CPs/CMs via PROFINET Of which Io devices with IRT, max.64- Number of connectable IO Devices, for RT, max.128. In total, up to 256 distributed I/O devices can be connected via CPs/CMs via PROFINET Of which Io devices sper tool, max.128. In total, up to 256 distributed I/O devices can be connected via CPs/CMs via PROFINET Of which IO devices with IRT, max.64- Number of IO Devices for RT, max.128. In total, up to 256 distributed I/O devices can be connected via CPs/CMs via PROFINET Of which II Devices for RT, max.128. In total, up to 256 distributed I/O devices can be connected via CPs/CMs via PROFINET Of which II Devices for RT, max.128. In total, up to 256 distributed I/O devices can be connected via CPs/CMs via PROFINET Of which II Devices for RT, max.128. In total, up to 256 distributed I/O devices can be connected via CPs/CMs via PROFINET Of which III Ine, max.8- Number of IO Devices per tool, max. </td <td></td> <td>Yes</td>		Yes
AutocrossingYesIndustrial Ethernet status LEDYesProtocolsNumber of connections, max.96Number of connections reserved for10ES/HMI/web64Number of connections via integrated64interfaces97PROFINET IO ControllerServices- PG/OP communicationYes- S7 routingYes- S7 routingYes- Soft communicationYes- Number of connectable I/O Devices, max.128, In total, up to 256 distributed I/O devices can be connected via CPa/CMs via PROFINET devices- PROFIenergyYes- PROFIenergyYes- Open IE communicationYes via CPa/CMs via PROFIBUS or PROFINET Of which I/O devices with IRT, max.64- Number of connectable I/O Devices for RT, max.128, In total, up to 256 distributed I/O devices can be connected via CPa/CMs via PROFIBUS or PROFINET Of which I O devices with IRT, max.64- Number of I/O Devices for RT, max.128- Number of I/O Devices for RT, max.128- Number of I/O Devices for RT, max.8- Number of I/O Devices for I can be simultaneously activated/deactivated, max.8- Number of I/O Devices for I can be simultaneously activated/deactivated, max.8- Number of I/O Devices for RT128- Number of I/O Devices for I can be simultaneously activated/deactivated, max.8- Number of I/O Devices for I can be simultaneously activated/deactivated, max.9- Number of I/O		Yes
• Industrial Ethernet status LED Yes Protocols Number of connections, max. 96 • Number of connections reserved for 10 ES/MI/Web 64 • Number of connections via integrated interfaces 64 PROFINET IO Controller Services - PG/OP communication Yes - S7 routing Yes - S7 routing Yes - S7 routing Yes - PROFINET IO controller Yes - PROFINET or communication Yes - PROFIenergy Yes - PROFIenergy Yes - PROFIenergy Yes - Or which IO devices with IRT, max. 64 - Number of connectable IO Devices for RT, max. 128. In total, up to 256 distributed I/O devices can be connected via CPS/CMS via PROFIBUS or PROFINET. - Of which ID devices with IRT, max. 64 - Number of IO Devices for RT, max. 128 - Of which in line, max. 128 - Of which in line, max. 8 - Number of IO Devices per tool, max. 8 - Number of IO Devices per tool, max. 8	-	Yes
Number of connections 96 • Number of connections, max. 96 • Number of connections reserved for ES/HMI/web 10 • Number of connections via integrated interfaces 64 PROFINET IO Controller 54 Services – PG/OP communication Yes — S7 routing Yes — lochronous mode Yes — Open IE communication Yes — Number of connectable IO Devices, max. 128. In total, up to 256 distributed I/O devices can be connected via CPs/CMs via PROFIBUS or PROFINET. — Of which IO devices with IRT, max. 64 — Number of connectable IO Devices, max. 128. — Number of IO Devices that can be simultaneously activated/deactivated, max. 128 — of which In line, max. 128. — Number of IO Devices per tool, max. 8 — Updating times The minimum value of the update time also depends on communication share set for PROFINET IO, on the number of IO devices, and on the quantity of configured user data Update time for IRT 250 µs to 4 ms — for send cycle of 250 µs 500 µs to 8 ms — for send cycle of 500 µs 500 µs to 8 ms — for send cycle of 1 ms 1 ms to 16 ms — for	-	Yes
Number of connections 96 • Number of connections, max. 96 • Number of connections reserved for ES/HMI/web 10 • Number of connections via integrated interfaces 64 PROFINET IO Controller 54 Services – PG/OP communication Yes — S7 routing Yes — lochronous mode Yes — Open IE communication Yes — Number of connectable IO Devices, max. 128. In total, up to 256 distributed I/O devices can be connected via CPs/CMs via PROFIBUS or PROFINET. — Of which IO devices with IRT, max. 64 — Number of connectable IO Devices, max. 128. — Number of IO Devices that can be simultaneously activated/deactivated, max. 128 — of which In line, max. 128. — Number of IO Devices per tool, max. 8 — Updating times The minimum value of the update time also depends on communication share set for PROFINET IO, on the number of IO devices, and on the quantity of configured user data Update time for IRT 250 µs to 4 ms — for send cycle of 250 µs 500 µs to 8 ms — for send cycle of 500 µs 500 µs to 8 ms — for send cycle of 1 ms 1 ms to 16 ms — for	Destanda	
 Number of connections reserved for ES/HMI/web Number of connections reserved for ES/HMI/web Number of connections via integrated interfaces PROFINET IO Controller Services PGOP communication \$7 routing Yes - S7 routing Yes - Open IE communication Yes - Open IE communication Yes - PROFIenergy Yes - PROFIenergy Yes - Prioritized startup Ves, 32 PROFINET devices - Number of connectable IO Devices, max. - Of which IO devices with IRT, max. - Of which IO devices with IRT, max. - of which IO devices that can be simultaneously activated/deactivated, max. - of which II line, max. - of which II line, max. - of which IO Devices per tool, max. - Number of IO Devices per tool, max. - Number of IO Devices per tool, max. - Updating times - for send cycle of 250 µs - for send cycle of 250 µs - for send cycle of 1 ms - for send cycle of 2 ms - The minimum value of the set of ms - for send cycle of 2 ms 		
• Number of connections reserved for ES/HMI/web10• Number of connections via integrated interfaces64• Number of conncollors64• PROFINET IO Controller•Services•- PG/OP communicationYes- Isochronous modeYes- Open IE communicationYes- Open IE communicationYes- PROFInergyYes- PROFInergyYes- PROFInergyYes- Of which IO devices, max.128. In total, up to 256 distributed I/O devices can be connected via CPs/CMs via PROFINET Of which IO devices with IRT, max.64- Number of connectable IO Devices for RT, max.128- of which II in ine, max.128- of which II ine, max.8- Number of IO Devices per tool, max.8- Number of IO Devices per tool, max.8- Updating timesThe minimum value of the update time also depends on communication share set for PROFINET IO, on the number of IO devices, and on the quantity of configured user data- for send cycle of 250 µs500 µs to 8 ms- for send cycle of 250 µs500 µs to 8 ms- for send cycle of 1 ms1 ms to 16 ms- for send cycle of 1 ms1 ms to 32 ms		96
Interfaces PROFINET IO Controller Services - - PG/OP communication Yes - S7 routing Yes - Isochronous mode Yes - Open IE communication Yes - Isochronous mode Yes - Open IE communication Yes - IRT Yes - PROFInergy Yes - PROFilenergy Yes - PROFilenergy Yes - Prioritized startup Yes; Max. 32 PROFIBUS or PROFIBUS or PROFINET. - Of which IO devices with IRT, max. 64 - Number of connectable IO Devices for RT, max. 128 - Of which ID devices that can be simultaneously activated/deactivated, max. 8 - Number of IO Devices that can be simultaneously activated/deactivated, max. 8 - Updating times The minimum value of the update time also depends on communication share set for PROFINET IO, on the number of IO devices, and on the quantity of configured user data Update time for IRT	 Number of connections reserved for 	10
Services - PG/OP communication Yes - S7 routing Yes - Isochronous mode Yes - Open IE communication Yes - IRT Yes - PROFlenergy Yes - Prioritized startup Yes; Max. 32 PROFINET devices - Number of connectable IO Devices, max. 128; In total, up to 256 distributed I/O devices can be connected via CPs/CMs via PROFIBUS or PROFINET. - Of which IO devices with IRT, max. 64 - Number of connectable IO Devices for RT, max. 128 - of which in line, max. 128 - of which in line, max. 128 - of which of IO Devices that can be simultaneously activated/deactivated, max. 128 - Number of IO Devices per tool, max. 8 - Updating times 8 - Updating times The minimum value of the update time also depends on communication share set for PROFINET IO, on the number of IO devices, and on the quantity of configured user data Update time for IRT – for send cycle of 250 μs 250 μs to 4 ms - for send cycle of 500 μs 500 μs to 8 ms – for send cycle of 1 ms - for send cycle of 2 ms 2 ms to 32 ms	_	64
- PG/OP communication Yes - S7 routing Yes - Isochronous mode Yes - Open IE communication Yes - IRT Yes - PROFlenergy Yes - Prioritized startup Yes; Max. 32 PROFINET devices - Number of connectable IO Devices, max. 128; In total, up to 256 distributed I/O devices can be connected via CPs/CMs via PROFIBUS or PROFINET. - Of which IO devices with IRT, max. 64 - Number of connectable IO Devices for RT, max. 128 - of which in line, max. 128 - of which in line, max. 128 - Number of IO Devices that can be simultaneously activated/deactivated, max. 8 - Number of IO Devices per tool, max. 8 - Updating times 8 Update time for IRT 250 µs to 4 ms - for send cycle of 250 µs 500 µs to 8 ms - for send cycle of 1 ms 1 ms to 16 ms - for send cycle of 2 ms 2 ms to 32 ms	PROFINET IO Controller	
 S7 routing Set of the set o	Services	
 Isochronous mode Isochronous mode Ves Open IE communication IRT PROFIenergy Prioritized startup Ves; Max. 32 PROFINET devices Prioritized startup Ves; Max. 32 PROFINET devices Number of connectable IO Devices, max. Of which IO devices with IRT, max. Of which IO devices with IRT, max. Of which in line, max. of which of IO Devices that can be simultaneously activated/deactivated, max. Number of IO Devices per tool, max. Updating times The minimum value of the update time also depends on communication share set for PROFINET IO, on the number of IO devices, and on the quantity of configured user data Update time for IRT for send cycle of 250 µs 250 µs to 4 ms for send cycle of 1 ms for send cycle of 2 ms 2 ms to 32 ms 	— PG/OP communication	Yes
IndextinationYes- Open IE communicationYes- IRTYes- PROFlenergyYes; Max. 32 PROFINET devices- Prioritized startupYes; Max. 32 PROFINET devices- Number of connectable IO Devices, max.128; In total, up to 256 distributed I/O devices can be connected via CPs/CMs via PROFIBUS or PROFINET Of which IO devices with IRT, max.64- Number of connectable IO Devices for RT, max.128- of which in line, max.128- of which in line, max.128- Number of IO Devices that can be simultaneously activated/deactivated, max.8- Updating timesThe minimum value of the update time also depends on communication share set for PROFINET IO, on the number of IO devices, and on the quantity of configured user dataUpdate time for IRT- for send cycle of 500 µs- for send cycle of 500 µs250 µs to 4 ms- for send cycle of 1 ms1 ms to 16 ms- for send cycle of 2 ms2 ms to 32 ms	— S7 routing	Yes
IRTYes- IRTYes- PROFlenergyYes; Max. 32 PROFINET devices- Prioritized startupYes; Max. 32 PROFINET devices- Number of connectable IO Devices, max.128; In total, up to 256 distributed I/O devices can be connected via CPs/CMs via PROFIBUS or PROFINET Of which IO devices with IRT, max.64- Number of connectable IO Devices for RT, max.128- of which in line, max.128- of which in line, max.128- of which in line, max.128- Number of IO Devices that can be simultaneously activated/deactivated, max.8- Number of IO Devices per tool, max.8- Updating timesThe minimum value of the update time also depends on communication share set for PROFINET IO, on the number of IO devices, and on the quantity of configured user dataUpdate time for IRT250 µs to 4 ms- for send cycle of 250 µs500 µs to 8 ms- for send cycle of 1 ms1 ms to 16 ms- for send cycle of 2 ms2 ms to 32 ms	— Isochronous mode	Yes
PROFIENERGYYes- PROFIENERGYYes; Max. 32 PROFINET devices- Prioritized startupYes; Max. 32 PROFINET devices- Number of connectable IO Devices, max.128; In total, up to 256 distributed I/O devices can be connected via CPs/CMs via PROFIBUS or PROFINET Of which IO devices with IRT, max.64- Number of connectable IO Devices for RT, max.128- of which in line, max.128- of which in line, max.8- Number of IO Devices that can be simultaneously activated/deactivated, max.8- Number of IO Devices per tool, max.8- Updating timesThe minimum value of the update time also depends on communication share set for PROFINET IO, on the number of IO devices, and on the quantity of configured user dataUpdate time for IRT250 µs to 4 ms- for send cycle of 250 µs500 µs to 8 ms- for send cycle of 1 ms1 ms to 16 ms- for send cycle of 2 ms2 ms to 32 ms	— Open IE communication	Yes
 Prioritized startup Prioritized startup Ves; Max. 32 PROFINET devices Number of connectable IO Devices, max. 128; In total, up to 256 distributed I/O devices can be connected via CPs/CMs via PROFIBUS or PROFINET. Of which IO devices with IRT, max. Of which IO devices of RT, max. Number of connectable IO Devices for RT, max. of which in line, max. of which in line, max. of which in line, max. Number of IO Devices that can be simultaneously activated/deactivated, max. Number of IO Devices per tool, max. Number of IO Devices per tool, max. Updating times The minimum value of the update time also depends on communication share set for PROFINET IO, on the number of IO devices, and on the quantity of configured user data Update time for IRT for send cycle of 250 µs for send cycle of 1 ms for send cycle of 2 ms 2 ms to 32 ms 	— IRT	Yes
- Number of connectable IO Devices, max.128; In total, up to 256 distributed I/O devices can be connected via CPs/CMs via PROFIBUS or PROFINET Of which IO devices with IRT, max.64- Number of connectable IO Devices for RT, max.128- of which in line, max.128- of which in line, max.128- Number of IO Devices that can be simultaneously activated/deactivated, max.8- Number of IO Devices per tool, max.8- Number of IO Devices per tool, max.7- Number of IO Devices per tool, max.8- Updating timesThe minimum value of the update time also depends on communication share set for PROFINET IO, on the number of IO devices, and on the quantity of configured user data- for send cycle of 250 µs250 µs to 4 ms- for send cycle of 500 µs500 µs to 8 ms- for send cycle of 1 ms1 ms to 16 ms- for send cycle of 2 ms2 ms to 32 ms	— PROFlenergy	Yes
 via CPs/CMs via PROFIBUS or PROFINET. Of which IO devices with IRT, max. Number of connectable IO Devices for RT, max. of which in line, max. of which in line, max. of which in Devices that can be simultaneously activated/deactivated, max. Number of IO Devices that can be simultaneously activated/deactivated, max. Number of IO Devices per tool, max. Updating times the minimum value of the update time also depends on communication share set for PROFINET IO, on the number of IO devices, and on the quantity of configured user data 	— Prioritized startup	Yes; Max. 32 PROFINET devices
- Number of connectable IO Devices for RT, max.128- of which in line, max.128- Number of IO Devices that can be simultaneously activated/deactivated, max.8- Number of IO Devices per tool, max.8- Number of IO Devices per tool, max.7- Updating timesThe minimum value of the update time also depends on communication share set for PROFINET IO, on the number of IO devices, and on the quantity of configured user dataUpdate time for IRT250 μs to 4 ms- for send cycle of 250 μs500 μs to 8 ms- for send cycle of 1 ms1 ms to 16 ms- for send cycle of 2 ms2 ms to 32 ms	 — Number of connectable IO Devices, max. 	
max.128— of which in line, max.128— Number of IO Devices that can be simultaneously activated/deactivated, max.8— Number of IO Devices per tool, max.8— Updating timesThe minimum value of the update time also depends on communication share set for PROFINET IO, on the number of IO devices, and on the quantity of configured user dataUpdate time for IRT250 μs to 4 ms— for send cycle of 250 μs500 μs to 8 ms— for send cycle of 1 ms1 ms to 16 ms— for send cycle of 2 ms2 ms to 32 ms	— Of which IO devices with IRT, max.	64
 Number of IO Devices that can be simultaneously activated/deactivated, max. Number of IO Devices per tool, max. Number of IO Devices per tool, max. Updating times Updating times The minimum value of the update time also depends on communication share set for PROFINET IO, on the number of IO devices, and on the quantity of configured user data Update time for IRT for send cycle of 250 µs for send cycle of 500 µs for send cycle of 1 ms ms to 16 ms ms to 32 ms 		128
 simultaneously activated/deactivated, max. Number of IO Devices per tool, max. Updating times Updating times The minimum value of the update time also depends on communication share set for PROFINET IO, on the number of IO devices, and on the quantity of configured user data Update time for IRT for send cycle of 250 µs for send cycle of 500 µs for send cycle of 1 ms for send cycle of 2 ms 2 ms to 32 ms 	— of which in line, max.	128
— Updating timesThe minimum value of the update time also depends on communication share set for PROFINET IO, on the number of IO devices, and on the quantity of configured user dataUpdate time for IRT250 μs to 4 ms— for send cycle of 250 μs250 μs to 4 ms— for send cycle of 500 μs500 μs to 8 ms— for send cycle of 1 ms1 ms to 16 ms— for send cycle of 2 ms2 ms to 32 ms		8
Communication share set for PROFINET IO, on the number of IO devices, and on the quantity of configured user dataUpdate time for IRT— for send cycle of 250 μs250 μs to 4 ms— for send cycle of 500 μs500 μs to 8 ms— for send cycle of 1 ms1 ms to 16 ms— for send cycle of 2 ms2 ms to 32 ms	— Number of IO Devices per tool, max.	8
— for send cycle of 250 μs250 μs to 4 ms— for send cycle of 500 μs500 μs to 8 ms— for send cycle of 1 ms1 ms to 16 ms— for send cycle of 2 ms2 ms to 32 ms	— Updating times	communication share set for PROFINET IO, on the number of IO
— for send cycle of 500 μs500 μs to 8 ms— for send cycle of 1 ms1 ms to 16 ms— for send cycle of 2 ms2 ms to 32 ms	Update time for IRT	
— for send cycle of 1 ms 1 ms to 16 ms — for send cycle of 2 ms 2 ms to 32 ms	— for send cycle of 250 μs	250 µs to 4 ms
— for send cycle of 2 ms 2 ms to 32 ms	— for send cycle of 500 μ s	500 µs to 8 ms
	— for send cycle of 1 ms	1 ms to 16 ms
- for send cycle of 4 ms 4 ms to 64 ms	— for send cycle of 2 ms	2 ms to 32 ms
	— for send cycle of 4 ms	4 ms to 64 ms

 With IRT and parameterization of "odd" send cycles 	Update time = set "odd" send clock (any multiple of 125 µs: 375 µs, 625 µs 3 875 µs)
Update time for RT	
— for send cycle of 250 μs	250 μs to 128 ms
— for send cycle of 500 µs	500 μs to 256 ms
— for send cycle of 1 ms	1 ms to 512 ms
— for send cycle of 2 ms	2 ms to 512 ms
— for send cycle of 4 ms	4 ms to 512 ms
PROFINET IO Device	
Services	
— PG/OP communication	Yes
— S7 routing	Yes
— Isochronous mode	Yes
— Open IE communication	Yes
— IRT	Yes
— PROFlenergy	Yes
Redundancy mode	
• MRP	Yes; as MRP redundancy manager and/or MRP client; max. number of devices in the ring: 50
SIMATIC communication	· · · ·
 S7 communication, as server 	Yes
 S7 communication, as client 	Yes
• User data per job, max.	See online help (S7 communication, user data size)
Open IE communication	
• TCP/IP	Yes
— Data length, max.	64 kbyte
 ISO-on-TCP (RFC1006) 	Yes
— Data length, max.	64 kbyte
• UDP	Yes
— Data length, max.	1 472 byte
• DHCP	No
• SNMP	Yes
• DCP	Yes
• LLDP	Yes
Web server	
• HTTP	Yes; Standard and user-defined pages
• HTTPS	Yes; Standard and user-defined pages
Further protocols	
• MODBUS	Yes; MODBUS TCP
Media redundancy	
 Switchover time on line break, typ. 	200 ms
 Number of stations in the ring, max. 	50

Isochronous mode	
Isochronous operation (application synchronized up	Yes
to terminal)	
Equidistance	Yes
S7 message functions	
Number of login stations for message functions, max.	32
Program alarms	Yes
Number of configurable program messages, max.	5 000
Number of simultaneously active program alarms	500
Test commissioning functions	
Status block	Yes; up to 8 simultaneously
Single step	No
Status/control	
 Status/control variable 	Yes
Variables	Inputs, outputs, memory bits, DB, times, counters
 Number of variables, max. 	
— of which status variables, max.	200; per job
— of which control variables, max.	200; per job
Forcing	
 Forcing, variables 	Inputs, outputs
 Number of variables, max. 	200
Diagnostic buffer	
● present	Yes
 Number of entries, max. 	
— of which powerfail-proof	500
Interrupts/diagnostics/status information	
Diagnostics indication LED	
• RUN/STOP LED	Yes
• ERROR LED	Yes
MAINT LED	Yes
 Connection display LINK TX/RX 	Yes
Supported technology objects	
Motion Control	Yes
 Speed-controlled axis 	
 Number of speed-controlled axes, max. 	6; Up to 6 axes in total (speed-controlled, positioning axis, external encoders) are supported
 Positioning axis 	
— Number of positioning axes, max.	6; Up to 6 axes in total (speed-controlled, positioning axis, external encoders) are supported
• External encoders	

Controller	
PID_Compact	Yes; Universal PID controller with integrated optimization
PID_3Step	Yes; PID controller with integrated optimization for valves
Counting and measuring	
High-speed counter	Yes
Ambient conditions	
Ambient temperature during operation	
 horizontal installation, min. 	-40 °C; = Tmin; Startup @ -20 °C
	60 °C; Display: 50 °C, at an operating temperature of typically 50 °C, the display is switched off
• vertical installation, min.	-40 °C; = Tmin; Startup @ -20 °C
 vertical installation, max. 	40 °C; Display: 40 °C, at an operating temperature of typically 40 °C, the display is switched off
Ambient temperature during storage/transportation	
• min.	-40 °C
• max.	70 °C
Altitude during operation relating to sea level	
 Installation altitude above sea level, max. 	5 000 m
altitude	Tmin Tmax at 1 140 hPa 795 hPa (-1 000 m +2 000 m) // Tmin (Tmax - 10 K) at 795 hPa 658 hPa (+2 000 m +3 500 m) // Tmin (Tmax -20 K) at 658 hPa 540 hPa (+3 500 m +5 000 m)
Relative humidity	
 With condensation, tested in accordance with IEC 60068-2-38, max. 	100 %; RH incl. condensation / frost (no commissioning in bedewed state), horizontal installation
Resistance	
Coolants and lubricants	
 Resistant to commercially available coolants and lubricants 	Yes; Incl. diesel and oil droplets in the air
Use in stationary industrial systems	
o ,	Yes; Class 3B2 mold, fungus and dry rot spores (with the exception of fauna); Class 3B3 on request
,	Yes; Class 3C4 (RH < 75 %) incl. salt spray acc. to EN 60068-2- 52 (severity degree 3); *
 — to mechanically active substances according to EN 60721-3-3 	Yes; Class 3S4 incl. sand, dust, *
Use on ships/at sea	
o y	Yes; Class 6B2 mold and fungal spores (excluding fauna); Class 6B3 on request
,	Yes; Class 6C3 (RH < 75 %) incl. salt spray acc. to EN 60068-2- 52 (severity degree 3); *

— to mechanically active substances according to EN 60721-3-6	Yes; Class 6S3 incl. sand, dust; *
Remark	
 — Note regarding classification of environmental conditions acc. to EN 60721, EN 60654-4 and ANSI/ISA-71.04 	* The supplied plug covers must remain in place over the unused interfaces during operation!
Conformal coating	
 Coatings for printed circuit board assemblies acc. to EN 61086 	Yes; Class 2 for high availability
 Military testing according to MIL-I-46058C, Amendment 7 	Yes; Discoloration of coating possible during service life
 Qualification and Performance of Electrical Insulating Compound for Printed Board Assemblies according to IPC-CC-830A 	Yes; Conformal coating, Class A
Configuration	
Programming	
Programming language	
— LAD	Yes
— FBD	Yes
— STL	Yes
— SCL	Yes
— GRAPH	Yes; As of STEP 7 V12 SP1
Know-how protection	
 User program protection/password protection 	Yes
Copy protection	Yes
Block protection	Yes
Access protection	
 Password for display 	Yes
 Protection level: Write protection 	Yes
 Protection level: Read/write protection 	Yes
 Protection level: Complete protection 	Yes
Cycle time monitoring	
lower limit	adjustable minimum cycle time
• upper limit	adjustable maximum cycle time
Dimensions	
Width	35 mm
Height	147 mm
Depth	129 mm
Weights	
Weight, approx.	430 g
Other	

Note:

At temperatures below 0 °C legibility may be restricted and representation of dynamic contents may be slower

last modified:

08/30/2019