## Data sheet



SIPLUS S7-1500 CPU 1513-1 PN -40...+70°C start up -20°C with conformal coating based on 6ES7513-1AL01-0AB0 . Central processing unit with Work memory 300 KB for program and 1.5 MB for data, 1st interface: PROFINET IRT with 2-port switch, 40 ns bit performance, SIMATIC Memory Card required

Figure similar

General information	
Product type designation	CPU 1513-1 PN
HW functional status	FS01
Firmware version	V1.8
Engineering with	
<ul> <li>STEP 7 TIA Portal configurable/integrated as of version</li> </ul>	V13 SP1 Update 4
Configuration control	
via dataset	Yes
Display	
Screen diagonal [cm]	3.45 cm
Control elements	
Number of keys	6
Mode selector switch	1
Supply voltage	
Type of supply voltage	24 V DC

permissible range, lower limit (DC)	19.2 V
permissible range, upper limit (DC)	28.8 V
Reverse polarity protection	Yes
Mains buffering	
Mains/voltage failure stored energy time	5 ms
Input current	
Current consumption (rated value)	0.7 A
Inrush current, max.	1.9 A; Rated value
l²t	0.02 A <sup>2</sup> ·s
Power	
Infeed power to the backplane bus	10 W
Power consumption from the backplane bus (balanced)	5.5 W
Power loss	
Power loss, typ.	5.7 W
Memory	
SIMATIC memory card required	Yes
Work memory	
• integrated (for program)	300 kbyte
• integrated (for data)	1.5 Mbyte
Load memory	
Plug-in (SIMATIC Memory Card), max.	32 Gbyte
Backup	
maintenance-free	Yes
CPU processing times	
for bit operations, typ.	40 ns
for word operations, typ.	48 ns
for fixed point arithmetic, typ.	64 ns
for floating point arithmetic, typ.	256 ns
CPU-blocks	
Number of elements (total)	2 000; In addition to blocks such as DBs, FBs and FCs, UDTs, global constants, etc. are also regarded as elements
DB	
Number range	1 60 999; subdivided into: number range that can be used by the user: 1 59 999, and number range of DBs created via SFC 86: 60 000 60 999
● Size, max.	1.5 Mbyte; For non-optimized block accesses, the max. size of the DB is 64 KB
FB	
Number range	0 65 535
• Size, max.	300 kbyte

FC	
Number range	0 65 535
• Size, max.	300 kbyte
ОВ	
• Size, max.	300 kbyte
Number of free cycle OBs	100
Number of time alarm OBs	20
Number of delay alarm OBs	20
<ul> <li>Number of cyclic interrupt OBs</li> </ul>	20
<ul> <li>Number of process alarm OBs</li> </ul>	50
<ul> <li>Number of DPV1 alarm OBs</li> </ul>	3
<ul> <li>Number of isochronous mode OBs</li> </ul>	1
Number of technology synchronous alarm OBs	2
<ul> <li>Number of startup OBs</li> </ul>	100
<ul> <li>Number of asynchronous error OBs</li> </ul>	4
<ul> <li>Number of synchronous error OBs</li> </ul>	2
<ul> <li>Number of diagnostic alarm OBs</li> </ul>	1
Nesting depth	
• per priority class	24
Counters, timers and their retentivity  S7 counter	0.040
Number	2 048
Retentivity	
— adjustable	Yes
IEC counter	According to the three deads are as a second
• Number	Any (only limited by the main memory)
Retentivity	Vos
— adjustable	Yes
S7 times	2 048
Number  Petentivity	2 010
Retentivity — adjustable	Yes
— adjustable  IEC timer	100
Number	Any (only limited by the main memory)
Retentivity	, (, ,
— adjustable	Yes
Data areas and their retentivity	400 lbs to locately and light and it
Retentive data area (incl. timers, counters, flags), max.	128 kbyte; In total; available retentive memory for bit memories, timers, counters, DBs, and technology data (axes): 88 KB
Flag	and to the control of
• Number, max.	16 kbyte

Data blocks  Retentivity adjustable  Retentivity preset  Local data  per priority class, max.  Address area  Number of IO modules  I/O address area  Inputs  Outputs  per integrated IO subsystem  — Inputs (volume)  — Outputs (volume)  per CM/CP  — Inputs (volume)  — Outputs (volume)  Subprocess images  Number of subprocess images, max.	Yes No  64 kbyte; max. 16 KB per block  2 048; max. number of modules / submodules  32 kbyte; All inputs are in the process image 32 kbyte; All outputs are in the process image  8 kbyte  8 kbyte  8 kbyte  8 kbyte
Retentivity preset  Local data  per priority class, max.  Address area  Number of IO modules  I/O address area  Inputs  Outputs  per integrated IO subsystem  — Inputs (volume)  — Outputs (volume)  per CM/CP  — Inputs (volume)  — Outputs (volume)  Subprocess images  Number of subprocess images, max.	No  64 kbyte; max. 16 KB per block  2 048; max. number of modules / submodules  32 kbyte; All inputs are in the process image 32 kbyte; All outputs are in the process image  8 kbyte  8 kbyte  8 kbyte
Retentivity preset  Local data  per priority class, max.  Address area  Number of IO modules  I/O address area  Inputs  Outputs  per integrated IO subsystem  — Inputs (volume)  — Outputs (volume)  per CM/CP  — Inputs (volume)  — Outputs (volume)  Subprocess images  Number of subprocess images, max.	64 kbyte; max. 16 KB per block  2 048; max. number of modules / submodules  32 kbyte; All inputs are in the process image 32 kbyte; All outputs are in the process image  8 kbyte  8 kbyte  8 kbyte
Local data  • per priority class, max.  Address area  Number of IO modules  I/O address area  • Inputs  • Outputs  per integrated IO subsystem  — Inputs (volume)  — Outputs (volume)  per CM/CP  — Inputs (volume)  — Outputs (volume)  Subprocess images  • Number of subprocess images, max.	2 048; max. number of modules / submodules  32 kbyte; All inputs are in the process image 32 kbyte; All outputs are in the process image  8 kbyte  8 kbyte
Number of IO modules  I/O address area  Inputs  Outputs  per integrated IO subsystem  — Inputs (volume)  — Outputs (volume)  per CM/CP  — Inputs (volume)  — Outputs (volume)  Subprocess images  Number of subprocess images, max.	2 048; max. number of modules / submodules  32 kbyte; All inputs are in the process image 32 kbyte; All outputs are in the process image  8 kbyte  8 kbyte
Number of IO modules  I/O address area  Inputs Outputs  Per integrated IO subsystem — Inputs (volume) — Outputs (volume)  per CM/CP — Inputs (volume) — Outputs (volume)  Subprocess images Number of subprocess images, max.	32 kbyte; All inputs are in the process image 32 kbyte; All outputs are in the process image  8 kbyte 8 kbyte 8 kbyte
Number of IO modules  I/O address area  Inputs Outputs  Per integrated IO subsystem — Inputs (volume) — Outputs (volume)  per CM/CP — Inputs (volume) — Outputs (volume)  Subprocess images Number of subprocess images, max.	32 kbyte; All inputs are in the process image 32 kbyte; All outputs are in the process image  8 kbyte 8 kbyte 8 kbyte
I/O address area  • Inputs  • Outputs  per integrated IO subsystem  — Inputs (volume)  — Outputs (volume)  per CM/CP  — Inputs (volume)  — Outputs (volume)  Subprocess images  • Number of subprocess images, max.	32 kbyte; All inputs are in the process image 32 kbyte; All outputs are in the process image  8 kbyte 8 kbyte 8 kbyte
Inputs  Outputs  per integrated IO subsystem  — Inputs (volume)  — Outputs (volume)  per CM/CP  — Inputs (volume)  — Outputs (volume)  Subprocess images  Number of subprocess images, max.	32 kbyte; All outputs are in the process image  8 kbyte  8 kbyte  8 kbyte
Outputs  per integrated IO subsystem  — Inputs (volume)  — Outputs (volume)  per CM/CP  — Inputs (volume)  — Outputs (volume)  Subprocess images  • Number of subprocess images, max.	32 kbyte; All outputs are in the process image  8 kbyte  8 kbyte  8 kbyte
per integrated IO subsystem  — Inputs (volume)  — Outputs (volume)  per CM/CP  — Inputs (volume)  — Outputs (volume)  Subprocess images  • Number of subprocess images, max.	8 kbyte 8 kbyte 8 kbyte
<ul> <li>— Inputs (volume)</li> <li>— Outputs (volume)</li> <li>per CM/CP</li> <li>— Inputs (volume)</li> <li>— Outputs (volume)</li> <li>Subprocess images</li> <li>• Number of subprocess images, max.</li> </ul>	8 kbyte  8 kbyte
— Outputs (volume) per CM/CP — Inputs (volume) — Outputs (volume)  Subprocess images  • Number of subprocess images, max.	8 kbyte  8 kbyte
per CM/CP  — Inputs (volume)  — Outputs (volume)  Subprocess images  • Number of subprocess images, max.	8 kbyte
— Inputs (volume)  — Outputs (volume)  Subprocess images  • Number of subprocess images, max.	
<ul><li>Outputs (volume)</li><li>Subprocess images</li><li>Number of subprocess images, max.</li></ul>	
Subprocess images  • Number of subprocess images, max.	8 круге
Number of subprocess images, max.	
Hardware configuration	32
Number of distributed IO systems	20
Number of DP masters	
● Via CM	6; A maximum of 6 CMs (PROFINET + PROFIBUS) can be inserted in total
Number of IO Controllers	
integrated	1
● Via CM	6; A maximum of 6 CMs (PROFINET + PROFIBUS) can be inserted in total
Rack	
Modules per rack, max.	32; CPU + 31 modules
Number of lines, max.	1
PtP CM	
Number of PtP CMs	the number of connectable PtP CMs is only limited by the number of available slots
Fime of day	
Clock	
• Type	Hardware clock
Backup time	6 wk; At 40 °C ambient temperature, typically
Deviation per day, max.	10 s; Typ.: 2 s
Operating hours counter	
• Number	16

Clock synchronization	
• supported	Yes
• in AS, master	Yes
• in AS, slave	Yes
• on Ethernet via NTP	Yes
Interfaces	
Number of PROFINET interfaces	1
1. Interface	
Interface types	
Number of ports	2
• integrated switch	Yes
• RJ 45 (Ethernet)	Yes; X1
Protocols	
PROFINET IO Controller	Yes
PROFINET IO Device	Yes
SIMATIC communication	Yes
Open IE communication	Yes
Web server	Yes
Media redundancy	Yes
Interfere trues	
Interface types  RJ 45 (Ethernet)	
• 100 Mbps	Yes
Autonegotiation	Yes
Autocrossing	Yes
Industrial Ethernet status LED	Yes
Dustanala	
Protocols  Number of connections	
Number of connections, max.	128; via integrated interfaces of the CPU and connected CPs /
Training of confidence, max.	CMs
<ul> <li>Number of connections reserved for</li> </ul>	10
ES/HMI/web	
<ul> <li>Number of connections via integrated interfaces</li> </ul>	88
<ul> <li>Number of S7 routing paths</li> </ul>	16
PROFINET IO Controller	
Services	
— PG/OP communication	Yes
— S7 routing	Yes
— Isochronous mode	Yes
— Open IE communication	Yes
— IRT	Yes

Prioritized startup  Number of connectable IO Devices, max.  Number of connectable IO Devices of RT, max.  Number of connectable IO Devices for RT, max.  of which In line, max.  I 28  Number of IO Devices that can be simultaneously activated/deactivated, max.  Number of IO Devices per tool, max.  Number of IO Toevices per tool, max.  Number of IO Toevice per tool, max.  Number of IO	— PROFlenergy	Yes
via PROFIBUS or PROFINET  Of which IO devices with IRT, max.  Number of connectable IO Devices for RT, max.  of which in line, max.  Number of IO Devices that can be simultaneously activated/deactivated, max.  Number of IO Devices per tool, max.  Number of IO Devices per tool, max.  Number of IO Devices per tool, max.  Updating times  The minimum value of the update time also depends on communication share set for PROFINET IO, on the number of IO devices, and on the quantity of configured user data  Update time for IRT  for send cycle of 250 µs  For send cycle of 500 µs  For send cycle of 1 ms  for send cycle of 1 ms  for send cycle of 2 ms  with IRT and parameterization of "odd"  send cycles  Update time for RT  for send cycle of 250 µs  for send cycle of 2 ms  for send cycle of 2 ms  for send cycle of 2 ms  for send cycle of 4 ms  for send cycle of 2 ms  for send cycle of 4 ms  for sen	<ul> <li>Prioritized startup</li> </ul>	Yes; Max. 32 PROFINET devices
- Number of connectable IO Devices for RT, max of which in line, max of which in line, max Number of IO Devices that can be simultaneously activated/deactivated, max Number of IO Devices per tool, max Updating times - Updating times - The minimum value of the update time also depends on communication share set for PROFINET IO, on the number of IO devices, and on the quantity of configured user data  Update time for IRT - for send cycle of 250 μs - for send cycle of 500 μs - for send cycle of 500 μs - for send cycle of 1 ms - for send cycle of 2 ms - for send cycle of 4 ms - With IRT and parameterization of "odd" send cycles  Update time for RT - for send cycle of 250 μs - for send cycle of 2 ms - for send cycle of 4 ms - for send cycle of 2 ms - for send cycle of 4 ms -	— Number of connectable IO Devices, max.	
max.  — of which in line, max.  — Number of IO Devices that can be simultaneously activated/deactivated, max.  — Number of IO Devices per tool, max.  — Updating times  The minimum value of the update time also depends on communication share set for PROFINET IO, on the number of IO devices, and on the quantity of configured user data  Update time for IRT  — for send cycle of 250 µs  — for send cycle of 500 µs  — for send cycle of 1 ms  — for send cycle of 2 ms  — for send cycle of 4 ms  — With IRT and parameterization of "odd" send cycle of 250 µs  — for send cycle of 500 µs  — for send cycle of 2 ms  — for send cycle of 4 ms  — with IRT and the set of the update time also depends on communication on the update time also depends on the update time also depends on communication on the update time also depends on communication on the update time also depends on communication on the update time also depends on the update time also depends on the update time also depends on communication on th	— Of which IO devices with IRT, max.	64
- of which in line, max.  - Number of IO Devices that can be simultaneously activated/deactivated, max.  - Number of IO Devices per tool, max.  - Updating times  - Updating times  - Update time for IRT  - for send cycle of 250 μs  - for send cycle of 1 ms  - for send cycle of 2 ms  - with IRT and parameterization of "odd" send cycle of 250 μs  - for send cycle of 250 μs  - for send cycle of 500 μs  - for send cycle of 2 ms  - for send cycle of 2 ms  - for send cycle of 500 μs  - for send cycle of 500 μs  - for send cycle of 4 ms  - With IRT and parameterization of "odd" send cycle of 500 μs  - for send cycle of 500 μs  - for send cycle of 250 μs  - for send cycle of 500 μs  - for send cycle of 4 ms  - for send cycle of 500 μs  - for send cycle of 4 ms  - for send cycle of 500 μs  - for send cycle of 500 μs	<ul> <li>Number of connectable IO Devices for RT,</li> </ul>	128
- Number of IO Devices that can be simultaneously activated/deactivated, max Number of IO Devices per tool, max Number of IO Devices per tool, max Updating times - The minimum value of the update time also depends on communication share set for PROFINET IO, on the number of IO devices, and on the quantity of configured user data    Update time for IRT	max.	
simultaneously activated/deactivated, max.  — Number of IO Devices per tool, max.  — Updating times  The minimum value of the update time also depends on communication share set for PROFINET IO, on the number of IO devices, and on the quantity of configured user data  Update time for IRT  — for send cycle of 250 μs  — for send cycle of 500 μs — for send cycle of 1 ms — for send cycle of 2 ms — for send cycle of 4 ms — with IRT and parameterization of "odd" send cycles — for send cycle of 250 μs — for send cycle of 250 μs — for send cycle of 250 μs — for send cycle of 4 ms — With IRT and parameterization of "odd" send cycles  Update time for RT — for send cycle of 250 μs — for send cycle of 500 μs — for send cycle of 4 ms — for send cycle of 500 μs — for send cycle of 4 ms — for send cycle of 500 μs — for send cycle of 500 μs — for send cycle of 4 ms — for send cycle of 4 ms — for send cycle of 4 ms — for send cycle of 500 μs — for send cycle of 500 μs — for send cycle of 4 ms — for send cycle of 4 ms — for send cycle of 500 μs — f	— of which in line, max.	128
The minimum value of the update time also depends on communication share set for PROFINET IO, on the number of IO devices, and on the quantity of configured user data  Update time for IRT  — for send cycle of 250 μs  250 μs to 4 ms; Note: In the case of IRT with isochronous mode, the minimum update time of 500 μs of the isochronous OB is decisive  — for send cycle of 500 μs  — for send cycle of 1 ms  — for send cycle of 2 ms  — for send cycle of 4 ms  — With IRT and parameterization of "odd" send cycles  Update time = set "odd" send clock (any multiple of 125 μs: 375 μs, 625 μs 3 875 μs)  Update time for RT  — for send cycle of 250 μs  — for send cycle of 500 μs  — for send cycle of 500 μs  — for send cycle of 500 μs  — for send cycle of 1 ms  — for send cycle of 1 ms  — for send cycle of 4 ms  — for send cycle of 4 ms  — for send cycle of 500 μs  — for send cycle of 4 ms  — for send cycle of 500 μs  — for sen		8
communication share set for PROFINET IO, on the number of IO devices, and on the quantity of configured user data  Update time for IRT  — for send cycle of 250 µs  — for send cycle of 500 µs — for send cycle of 500 µs — for send cycle of 1 ms — for send cycle of 1 ms — for send cycle of 2 ms — for send cycle of 4 ms — With IRT and parameterization of "odd" send cycles  — with IRT and parameterization of "odd" send cycle of 250 µs — for send cycle of 250 µs — for send cycle of 500 µs — for send cycle of 1 ms — for send cycle of 1 ms — for send cycle of 2 ms — for send cycle of 2 ms — for send cycle of 4 ms — for send cycle of 2 ms — for send cycle of 2 ms — for send cycle of 4 ms — for send cycle of 4 ms  PROFINET IO Device  Services  — PG/OP communication — S7 routing — Isochronous mode — Open IE communication — Yes — IRT — PROFIenergy — Shared device — Number of IO Controllers with shared device, max.	<ul> <li>Number of IO Devices per tool, max.</li> </ul>	8
— for send cycle of 250 μs  — for send cycle of 500 μs — for send cycle of 500 μs — for send cycle of 500 μs — for send cycle of 1 ms — for send cycle of 2 ms — for send cycle of 4 ms — with IRT and parameterization of "odd" send cycles — With IRT and parameterization of "odd" send cycles  — for send cycle of 250 μs — for send cycle of 500 μs — for send cycle of 500 μs — for send cycle of 500 μs — for send cycle of 250 μs — for send cycle of 1 ms — for send cycle of 2 ms — for send cycle of 2 ms — for send cycle of 4 ms  — for send cycle of 4 ms  — for send cycle of 500 μs — for send cycle of 2 ms — for send cycle of 4 ms  — for send cycle of 4 ms  — prof send cycle of 4 ms  — prof send cycle of 4 ms  — prof send cycle of 4 ms  — for send cycle of 500 μs — for send	— Updating times	communication share set for PROFINET IO, on the number of IO
the minimum update time of 500 µs of the isochronous OB is decisive  — for send cycle of 500 µs — for send cycle of 1 ms — for send cycle of 2 ms — for send cycle of 2 ms — for send cycle of 4 ms — with IRT and parameterization of "odd" — With IRT and parameterization of "odd" — With IRT and parameterization of "odd" — Update time = set "odd" send clock (any multiple of 125 µs: 375 µs, 625 µs 3 875 µs)  Update time for RT — for send cycle of 250 µs — for send cycle of 500 µs — for send cycle of 1 ms — for send cycle of 2 ms — for send cycle of 4 ms — for send cycle of 4 ms — the send cycle of 4 ms — for send cycle of 4 ms — for send cycle of 4 ms — for send cycle of 4 ms — the send cycle of 4 ms  PROFINET IO Device  Services  — PG/OP communication — S7 routing — Isochronous mode — Open IE communication — Yes — IRT — PROFlenergy — Shared device — Number of IO Controllers with shared device, max.  He minimum update time of 500 µs to 250 µs ms  1 ms to 16 ms  1 ms to 54 ms  2 ms to 512 ms  2 ms to 512 ms  PROFlore in a controller with shared device, max.	Update time for IRT	
— for send cycle of 1 ms — for send cycle of 2 ms — for send cycle of 4 ms — with IRT and parameterization of "odd" send cycles  Update time = set "odd" send clock (any multiple of 125 μs: 375 μs, 625 μs 3 875 μs)  Update time for RT  — for send cycle of 250 μs — for send cycle of 500 μs — for send cycle of 1 ms — for send cycle of 1 ms — for send cycle of 2 ms — for send cycle of 2 ms — for send cycle of 4 ms — for send cycle of 4 ms  PROFINET IO Device  Services  — PG/OP communication — S7 routing — Isochronous mode — Open IE communication — Yes — IRT — PROFlenergy — Shared device — Number of IO Controllers with shared device, max.	— for send cycle of 250 μs	the minimum update time of 500 $\mu s$ of the isochronous OB is
— for send cycle of 2 ms — for send cycle of 4 ms — With IRT and parameterization of "odd" send cycles  Update time = set "odd" send clock (any multiple of 125 μs: 375 μs, 625 μs 3 875 μs)  Update time for RT  — for send cycle of 250 μs — for send cycle of 500 μs — for send cycle of 500 μs — for send cycle of 1 ms — for send cycle of 1 ms — for send cycle of 4 ms — for send cycle of 4 ms — for send cycle of 4 ms — for send cycle of 500 μs	— for send cycle of 500 μs	500 μs to 8 ms
- for send cycle of 4 ms - With IRT and parameterization of "odd" send cycles	— for send cycle of 1 ms	1 ms to 16 ms
- With IRT and parameterization of "odd" send cycles ps. 375 μs, 625 μs 3 875 μs)  Update time for RT  - for send cycle of 250 μs 250 μs to 128 ms - for send cycle of 500 μs 500 μs to 256 ms - for send cycle of 1 ms 1 ms to 512 ms - for send cycle of 2 ms 2 ms to 512 ms - for send cycle of 4 ms 4 ms to 512 ms  PROFINET IO Device  Services  - PG/OP communication Yes Yes S7 routing Yes No Open IE communication Yes Yes PROFlenergy Yes Shared device Yes No No Shared device Yes No No No No No Shared device Yes No	— for send cycle of 2 ms	2 ms to 32 ms
send cycles  Update time for RT  — for send cycle of 250 μs — for send cycle of 500 μs 500 μs to 256 ms — for send cycle of 1 ms — for send cycle of 1 ms 1 ms to 512 ms — for send cycle of 2 ms — for send cycle of 4 ms 2 ms to 512 ms  PROFINET IO Device  Services  — PG/OP communication — S7 routing — Isochronous mode — Open IE communication — IRT — PROFlenergy — Shared device — Number of IO Controllers with shared device, max.	— for send cycle of 4 ms	4 ms to 64 ms
- for send cycle of 250 μs - for send cycle of 500 μs - for send cycle of 500 μs - for send cycle of 1 ms - for send cycle of 2 ms - for send cycle of 2 ms - for send cycle of 4 ms - for send cycle of 2 ms - for send cycle of 3 ms - for send cycle of 2 ms - for send cycle of 3 ms - for send cycle of 3 ms - for send cycle of 3 ms - for send cycle of 4 ms - for send cyc		
— for send cycle of 500 μs — for send cycle of 1 ms — for send cycle of 2 ms — for send cycle of 2 ms — for send cycle of 4 ms 2 ms to 512 ms — for send cycle of 4 ms 4 ms to 512 ms  PROFINET IO Device  Services  — PG/OP communication — S7 routing — Isochronous mode — Open IE communication — IRT — PROFlenergy — Shared device — Number of IO Controllers with shared device, max.	Update time for RT	
- for send cycle of 1 ms - for send cycle of 2 ms - for send cycle of 4 ms 2 ms to 512 ms - for send cycle of 4 ms 4 ms to 512 ms  PROFINET IO Device  Services  - PG/OP communication - S7 routing - Isochronous mode - Open IE communication - IRT - PROFIenergy - Shared device - Number of IO Controllers with shared device, max.	— for send cycle of 250 μs	250 μs to 128 ms
- for send cycle of 2 ms - for send cycle of 4 ms 4 ms to 512 ms  PROFINET IO Device  Services  - PG/OP communication - S7 routing - Isochronous mode - Open IE communication - IRT - PROFIenergy - Shared device - Number of IO Controllers with shared device, max.	— for send cycle of 500 μs	500 μs to 256 ms
— for send cycle of 4 ms 4 ms to 512 ms  PROFINET IO Device  Services  — PG/OP communication Yes — S7 routing Yes — Isochronous mode No — Open IE communication Yes — IRT Yes — PROFlenergy Yes — Shared device Yes — Number of IO Controllers with shared device, max.	— for send cycle of 1 ms	1 ms to 512 ms
PROFINET IO Device  Services  - PG/OP communication Yes - S7 routing Yes - Isochronous mode No - Open IE communication Yes - IRT Yes - PROFlenergy Yes - Shared device Yes - Number of IO Controllers with shared device, max.	— for send cycle of 2 ms	2 ms to 512 ms
Services  - PG/OP communication Yes - S7 routing Yes - Isochronous mode No - Open IE communication Yes - IRT Yes - PROFlenergy Yes - Shared device Yes - Number of IO Controllers with shared device, max.	— for send cycle of 4 ms	4 ms to 512 ms
<ul> <li>— PG/OP communication</li> <li>— S7 routing</li> <li>— Isochronous mode</li> <li>— Open IE communication</li> <li>— IRT</li> <li>— PROFlenergy</li> <li>— Shared device</li> <li>— Number of IO Controllers with shared device, max.</li> </ul>	PROFINET IO Device	
- S7 routing - Isochronous mode - Open IE communication - IRT - PROFlenergy - Shared device - Number of IO Controllers with shared device, max.  Yes - Number of IO Controllers with shared device, max.	Services	
<ul> <li>— Isochronous mode</li> <li>— Open IE communication</li> <li>— IRT</li> <li>— PROFlenergy</li> <li>— Shared device</li> <li>— Number of IO Controllers with shared device, max.</li> </ul>	— PG/OP communication	Yes
<ul> <li>Open IE communication</li> <li>IRT</li> <li>PROFlenergy</li> <li>Shared device</li> <li>Number of IO Controllers with shared device, max.</li> </ul>	— S7 routing	Yes
— IRT Yes  — PROFlenergy Yes  — Shared device Yes  — Number of IO Controllers with shared device, max.	— Isochronous mode	No
— PROFlenergy Yes  — Shared device Yes  — Number of IO Controllers with shared device, max.	<ul> <li>Open IE communication</li> </ul>	Yes
— Shared device Yes  — Number of IO Controllers with shared device, max.	— IRT	Yes
— Number of IO Controllers with shared device, max.	— PROFlenergy	Yes
device, max.	— Shared device	Yes
Redundancy mode		4
	Redundancy mode	

• MRP	Yes; as MRP redundancy manager and/or MRP client; max. number of devices in the ring: 50
SIMATIC communication	
<ul> <li>S7 communication, as server</li> </ul>	Yes
<ul> <li>S7 communication, as client</li> </ul>	Yes
User data per job, max.	See online help (S7 communication, user data size)
Open IE communication	
• TCP/IP	Yes
— Data length, max.	64 kbyte
<ul> <li>several passive connections per port, supported</li> </ul>	Yes
• ISO-on-TCP (RFC1006)	Yes
— Data length, max.	64 kbyte
• UDP	Yes
— Data length, max.	1 472 byte
• DHCP	No
• SNMP	Yes
• DCP	Yes
• LLDP	Yes
Web server	
• HTTP	Yes; Standard and user-defined pages
• HTTPS	Yes; Standard and user-defined pages
Further protocols	
• MODBUS	Yes; MODBUS TCP
Media redundancy	
<ul> <li>Switchover time on line break, typ.</li> </ul>	200 ms
<ul> <li>Number of stations in the ring, max.</li> </ul>	50
Isochronous mode	
Isochronous operation (application synchronized up to terminal)	Yes; With minimum OB 6x cycle of 625 μs
Equidistance	Yes
S7 message functions	
Number of login stations for message functions, max.	32
Program alarms	Yes
Number of configurable program messages, max.	5 000
Number of simultaneously active program alarms	
<ul> <li>Number of program alarms</li> </ul>	300
<ul> <li>Number of alarms for system diagnostics</li> </ul>	100
<ul> <li>Number of alarms for motion technology objects</li> </ul>	80
Test commissioning functions	

Joint commission (Team Engineering)	Yes; Parallel online access possible for up to 5 engineering systems
Status block	Yes; Up to 8 simultaneously (in total across all ES clients)
Single step	No
Status/control	
Status/control variable	Yes
Variables	Inputs/outputs, memory bits, DBs, distributed I/Os, timers, counters
<ul> <li>Number of variables, max.</li> </ul>	
— of which status variables, max.	200; per job
<ul><li>of which control variables, max.</li></ul>	200; per job
Forcing	
Forcing, variables	Peripheral inputs/outputs
Number of variables, max.	200
Diagnostic buffer	
• present	Yes
Number of entries, max.	1 000
— of which powerfail-proof	500
Traces	
Number of configurable Traces	4; Up to 512 KB of data per trace are possible
Interrupts/diagnostics/status information	
Diagnostics indication LED	
RUN/STOP LED	Yes
• ERROR LED	Yes
MAINT LED	Yes
<ul> <li>Connection display LINK TX/RX</li> </ul>	Yes
Supported technology objects	
Motion Control	Yes
Speed-controlled axis	
<ul> <li>Number of speed-controlled axes, max.</li> </ul>	6; Requirement: There must be no other motion technology objects created; note: The number of axes affects the cycle time of the PLC program; selection guide via the TIA Selection Tool
Positioning axis	
<ul> <li>Number of positioning axes, max.</li> </ul>	6; Requirement: There must be no other motion technology objects created; note: The number of axes affects the cycle time of the PLC program; selection guide via the TIA Selection Tool
<ul> <li>Synchronized axes (relative gear synchronization)</li> </ul>	
— Number of axes, max.	3; Requirement: There must be no other motion technology objects created; note: The number of axes affects the cycle time of the PLC program; selection guide via the TIA Selection Tool
<ul> <li>External encoders</li> </ul>	

— Number of external encoders, max.	6; Requirement: There must be no other motion technology objects created; note: The number of axes affects the cycle time of the PLC program; selection guide via the TIA Selection Tool
Controller	
<ul><li>PID_Compact</li></ul>	Yes; Universal PID controller with integrated optimization
PID_3Step	Yes; PID controller with integrated optimization for valves
• PID-Temp	Yes; PID controller with integrated optimization for temperature
Counting and measuring	
High-speed counter	Yes

Ambient conditions	
Ambient temperature during operation	
• horizontal installation, min.	-40 °C; = Tmin (incl. condensation/frost); start-up @ -20 °C
• horizontal installation, max.	70 °C; Display: 50 °C, at an operating temperature of typically 50 °C, the display is switched off
• vertical installation, min.	-40 °C; = Tmin; Startup @ -20 °C
• vertical installation, max.	40 °C; Display: 40 °C, at an operating temperature of typically 40 °C, the display is switched off
Ambient temperature during storage/transportation	
• min.	-40 °C
• max.	70 °C
Altitude during operation relating to sea level	
<ul> <li>Installation altitude above sea level, max.</li> </ul>	5 000 m
<ul> <li>Ambient air temperature-barometric pressure- altitude</li> </ul>	Tmin Tmax at 1 140 hPa 795 hPa (-1 000 m +2 000 m) // Tmin (Tmax - 10 K) at 795 hPa 658 hPa (+2 000 m +3 500 m) // Tmin (Tmax -20 K) at 658 hPa 540 hPa (+3 500 m +5 000 m)
Relative humidity	
<ul> <li>With condensation, tested in accordance with IEC 60068-2-38, max.</li> </ul>	100 %; RH incl. condensation / frost (no commissioning in bedewed state), horizontal installation
Resistance	
Coolants and lubricants	
<ul> <li>Resistant to commercially available coolants and lubricants</li> </ul>	Yes; Incl. diesel and oil droplets in the air
Use in stationary industrial systems	
<ul> <li>to biologically active substances according to EN 60721-3-3</li> </ul>	Yes; Class 3B2 mold, fungus and dry rot spores (with the exception of fauna); Class 3B3 on request
<ul> <li>to chemically active substances according to EN 60721-3-3</li> </ul>	Yes; Class 3C4 (RH < 75 %) incl. salt spray acc. to EN 60068-2-52 (severity degree 3); $^{\star}$
<ul> <li>to mechanically active substances according to EN 60721-3-3</li> </ul>	Yes; Class 3S4 incl. sand, dust, *
Use on ships/at sea	
<ul> <li>to biologically active substances according to EN 60721-3-6</li> </ul>	Yes; Class 6B2 mold and fungal spores (excluding fauna); Class 6B3 on request

Yes; Class 6C3 (RH < 75 %) incl. salt spray acc. to EN 60068-2-— to chemically active substances according to EN 60721-3-6 52 (severity degree 3); \* Yes; Class 6S3 incl. sand, dust; \* — to mechanically active substances according to EN 60721-3-6 Usage in industrial process technology Yes; Class 3 (excluding trichlorethylene) Against chemically active substances acc. to EN 60654-4 Yes; Level GX group A/B (excluding trichlorethylene; harmful gas - Environmental conditions for process, concentrations up to the limits of EN 60721-3-3 class 3C4 measuring and control systems acc. to permissible); level LC3 (salt spray) and level LB3 (oil) ANSI/ISA-71.04 Remark \* The supplied plug covers must remain in place over the unused - Note regarding classification of interfaces during operation! environmental conditions acc. to EN 60721, EN 60654-4 and ANSI/ISA-71.04 Conformal coating Yes; Class 2 for high availability · Coatings for printed circuit board assemblies acc. to EN 61086 Yes; Type 1 protection • Protection against fouling acc. to EN 60664-3 Yes; Discoloration of coating possible during service life Military testing according to MIL-I-46058C, Amendment 7 Yes; Conformal coating, Class A • Qualification and Performance of Electrical Insulating Compound for Printed Board

Configuration		
Programming		
Programming language		
— LAD	Yes	
— FBD	Yes	
— STL	Yes	
— SCL	Yes	
— GRAPH	Yes	
Know-how protection		
<ul> <li>User program protection/password protection</li> </ul>	Yes	
Copy protection	Yes	
<ul> <li>Block protection</li> </ul>	Yes	
Access protection		
Password for display	Yes	
<ul> <li>Protection level: Write protection</li> </ul>	Yes	
<ul> <li>Protection level: Read/write protection</li> </ul>	Yes	
<ul> <li>Protection level: Complete protection</li> </ul>	Yes	
Cycle time monitoring		
• lower limit	adjustable minimum cycle time	
• upper limit	adjustable maximum cycle time	

Assemblies according to IPC-CC-830A

Dimensions	
Width	70 mm
Height	147 mm
Depth	129 mm
Weights	
Weight, approx.	615 g
Other	
Note:	At temperatures below 0 °C legibility may be restricted and representation of dynamic contents may be slower
last modified:	08/30/2019